




California Regional Water Quality Control Board Central Valley Region

Winston H. Hickox
Secretary for
Environmental
Protection

Sacramento Main Office
Internet Address: <http://www.swrcb.ca.gov/~rwqcb5>
3443 Routier Road, Suite A, Sacramento, California 95827-3003
Phone (916) 255-3000 • FAX (916) 255-3015

Gra,
Gove.




18 December 2000

Mr. David Brown
Pacific Bell
3707 Kings Way, Room B15
Sacramento, CA 95851

ABOVEGROUND PETROLEUM STORAGE TANK INSPECTION, PACIFIC BELL, INCORPORATED, SACRAMENTO COUNTY

On 30 November 2000, I inspected the aboveground petroleum storage tank at 3600 Marconi Ave., Sacramento. The EnviroVault (double-walled) 1,000-gallon tank, which provides a diesel supply for your power equipment, has been well maintained and is in compliance with the provisions of the Aboveground Petroleum Storage Act.

If you have any questions, you may call me at (916) 255-3029.


G. ARNOLD INOUE
Sanitary Engineering Associate

cc: Sacramento County Environmental Management Department, Sacramento