

Countywide Services Agency
Environmental Management
Department
Hazardous Materials Division
Dennis Green, Chief



County of Sacramento

Terry Schutten, County Executive
Penelope Clarke, Agency
Administrator
Val F. Siebal, Department Director

February 9, 2007

James Wagner
11100 Center Avenue
Gilroy CA 95020

**RE: 1 UNDERGROUND STORAGE TANK REMOVAL AT
6542 FAIR OAKS BLVD CARMICHAEL CA 95608
REMOVAL AUTHORITY NUMBER: R07-006**

Please refer to your application to remove the tank at the site address listed above.

REMOVAL AUTHORITY

Authorization to remove the tank is hereby granted with the following conditions:

1. The Environmental Management Department (EMD), Hazardous Materials Division (HMD), shall be notified at least 48 hours prior to removal. Inspection completion is subject to the availability of Environmental Specialists. It is strongly recommended that notice be given as early as possible. **Please have the removal authority number and site address ready when calling for your inspection appointment at 875-8550.** Tank shall not be removed unless a representative from HMD is on site.
2. All encroachment, access or other permits (public agency or private) shall be the responsibility of the property owner/operator/contractor (or agent of) to research and obtain, prior to removing the tank.
3. Tank shall be rinsed and inerted prior to removal.
4. Comply with the conditions set forth under Sections II & III of the "Consolidated Application for Authority to Remove Underground Storage Tanks."
5. The cutting of tank on-site is prohibited (City of Sacramento Ordinance 7902.1.7.4.1., and Sacramento County Code, Chapter 17.04).
6. Soil analytical results, performed by certified labs, must be forwarded to EMD as soon as possible (analytical results shall include copies of chain-of-custody, lab quality control data, and sampling plot map).

James Wagner
February 9, 2007
Page 2

7. ***This removal authority expires six months from the date of this letter.*** Commencing work under this authority to remove the tank shall be deemed acceptance of all the conditions specified. This authorization does not allow violations of any applicable state or local rule, regulation, or code. The owner shall be deemed responsible to secure the property and excavation from unauthorized personnel at all times.

If you have any questions, please call Jonathan Pollack at (916) 876-7881.

Sincerely,



Dennis Green
Chief, Hazardous Materials Division

DG:JP:jm

c: RAH Environmental, Inc.
4645 Raley Blvd.
Sacramento CA 95838

W:\Data\Pollack\UST Removals\6542 FAIR OAKS BLVD.REM.doc