

FA0008940

Notify the Environmental Management Department of any change of ownership, type of business activity, business name, or billing address by calling 916-875-8550. Failure to notify Environmental Management may result in late penalties, Permit denial or revocation, and business closure. PERMITS TO OPERATE AND ANNUAL FEE PAYMENTS ARE NOT TRANSFERABLE. Permits become void on change of ownership. New owners must apply and pay for a new Permit(s) prior to beginning operation.

**YOUR PERMIT MUST BE
RETAINED ON THE PREMISES**

ATTN: MICHELLE PONCE, PERMIT ANALYST
CAMPUS SHELL D1-6678-83
20945 S WILMINGTON AVE
CARSON CA 90810

DETACH FORM HERE



**COUNTY OF SACRAMENTO
ENVIRONMENTAL MANAGEMENT DEPARTMENT
8475 JACKSON RD STE 230
SACRAMENTO CA 95826
(916) 875-8550**

REGULATED FACILITY :

**CAMPUS SHELL D1-6678-83
2270 FAIR OAKS BLVD
SACRAMENTO, CA 95825**

Facility ID: FA0008940
Account ID: AR0019129
Issued: 10/22/2004

OWNER NAME :

DALE MILES SHELL OIL PRODUCTS US

PERMITTED OPERATION(S):

5204 HAZARDOUS MATLS DISCLOSURE FEE 4-6 MATLS
VALID FROM SEPTEMBER 16, 2004 TO SEPTEMBER 16, 2005

5307 HAZARDOUS WASTE GENERATOR FEE 1200-12000 GAL
VALID FROM SEPTEMBER 16, 2004 TO SEPTEMBER 16, 2005

5414 UNDERGROUND STORAGE TANK FEE - 4 TANKS
VALID FROM SEPTEMBER 16, 2004 TO SEPTEMBER 16, 2005

Permits to operate and Annual Fee Payments are NOT TRANSFERABLE. Those referenced above are valid ONLY for this owner DALE MILES. Permits become VOID on change of ownership. New owners must apply and pay for a new Permit(s) PRIOR to beginning operation or penalties will be assessed.



COUNTY OF SACRAMENTO
Environmental Management Department
Mel Knight, Director

Bonnie Coleman, Manager
Administrative Services
Richard Sanchez, Chief
Environmental Health
Dennis Green, Chief
Hazardous Materials

PERMIT TO OPERATE
UNDERGROUND STORAGE TANK(S)
ADDENDUM TO CONSOLIDATED PERMIT

Facility Name: CAMPUS SHELL D1-6678-83 SHELL OIL PRODUCTS
US
Facility Address: 2270 FAIR OAKS BLVD
UST Owner: EQUILON/SHELL OIL PRODUCTS CO
UST Owner Address: AURA MATTIS
P O BOX 8080, MARTINEZ CA 94553
Envision Facility ID#: FA0008940
UST Permit Issue Date: September 16, 2004
UST Permit Expiration: September 16, 2005

UST Monitoring Requirements: The permit holder must comply with an approved written monitoring and response plan submitted to this office. (23 CCR, Sections 2632, 2634, and 2641(h))

UST ID Number	Product	CAPACITY	
	PREMIUM UNLEADED	10,000	Gallons
	REGULAR UNLEADED	10,000	Gallons
	WASTE OIL	550	Gallons
	MIDGRADE UNLEADED	10,000	Gallons

In order to maintain the Permit to Operate, the permit holder must comply with the permit conditions specified on the following pages. The owner and operator are subject to all applicable requirements of Chapters 6.7 and 6.75, Division 20 of the California Health and Safety Code and Title 23, Division 3, Chapters 16 and 18 of the California Code of Regulations.

See **PERMIT CONDITIONS** on Following page(s).

8475 Jackson Rd, Suite 230 - Sacramento CA 95826-3904 - (916) 875-8550 - FAX (916) 875-8513

PERMIT CONDITIONS

- (a) As a condition of any permit to operate an underground storage tank, the owner or operator shall comply with the reporting and recording requirements for unauthorized releases specified in CCR, Article 5, Title 23, Chapter 16.
- (b) Written monitoring and maintenance records shall be maintained on-site or off-site at a readily available location, if approved by the Environmental Management Department (EMD), for a period of at least 3 years, 6 ½ years for cathodic protection maintenance records, and 5 years for written performance claims pertaining to release detection systems, and calibration and maintenance records for such systems. Records of repairs, lining, and upgrades shall be maintained on site or at another approved location for the remaining life of the underground storage tank. These records shall be made available, upon request within 36 hours, to the EMD or the State Water Board. Monitoring records shall include:
- (1) The date and time of all monitoring or sampling;
 - (2) Monitoring equipment calibration and maintenance records;
 - (3) The results of any visual observations;
 - (4) The results of all sample analysis performed in the laboratory or in the field, including laboratory data sheets and analysis used;
 - (5) The logs of all reading of gauges or other monitoring equipment, ground water elevations, or other test results; and
 - (6) The results of inventory readings and reconciliations.
- (c) A permit to operate issued by the EMD shall be effective for one (1) year. In addition to other information specified by the EMD, the permit shall include the permit expiration date, monitoring requirements, and the state underground storage tank identification number(s) for which the permit was issued. Before the EMD issues a new permit or renewal to operate an underground storage tank, the EMD shall inspect the underground storage tank and determine that it complies with the provisions of these regulations.
- (d) The EMD shall not renew an underground storage tank permit unless the underground storage tank has been inspected by the EMD within the previous twelve (12) months and the inspection verifies that the underground storage tank complies with the provisions of CCR, Article 3 or 4, Title 23, as applicable, with all existing permit conditions. The inspection shall be conducted as specified in the appropriate subsection of Chapter 6.7 of Division 20 of the Health and Safety Code. If the inspection indicated noncompliance then the EMD shall verify by a follow-up inspection that all required corrections have been implemented before renewing the permit.
- (e) Within 30 calendar days of receiving an inspection report from EMD, the permit holder shall implement the corrections specified in the inspection report and comply with all the permit conditions. The corrective action shall include all of the recommendations made by the EMD. The EMD may waive the implementation of recommendations based on a demonstration by the permit holder to the EMD's satisfaction that failure to implement the recommendation will not cause an unauthorized release.
- (f) The EMD shall take appropriate enforcement action pursuant to section 25299 of the Health and Safety Code or prohibit the operation of the tank systems if the owner or operator fails to comply with the monitoring requirements in CCR, Article 3 or 4 or the reporting requirements of CCR, Article 5, Title 23.
- (g) A copy of the permit and all conditions and attachments, including monitoring plans, shall be retained at the facility.
- (h) All primary containment shall be product-tight
- (i) Owners and operators shall use care to prevent releases due to spilling or overfilling. Before product is delivered, owners, operators, or their agents shall ensure that the space available in the tank is greater than the volume of product to be transferred to the tank and shall ensure that the transfer operation is monitored constantly to prevent overfilling and spilling.
- (j) Approval must be obtained from the EMD prior to modifying any UST system in any way (including piping) regulated under the California Underground Tank Regulations, CCR, Title 23.

Authority: Sections 25299.3 and 25299.7, Health and Safety Code.

Reference: Sections 25284, 25285, 25286, 25288, 25289, 25293, and 25294, Health and Safety Code; 40 CFR 280.31(d), 280.33(f), 280.45 and 281.32(e).