

COUNTY OF SACRAMENTO  
ENVIRONMENTAL MANAGEMENT DEPARTMENT  
ENVIRONMENTAL COMPLIANCE DIVISION  
10590 ARMSTRONG AVENUE  
MATHER CA 95655  
(916) 875-0083 • FAX (916) 854-9274

## BACKFLOW ASSEMBLY TEST REPORT

### ASSEMBLY INFORMATION

TYPE: RP SIZE: 2.00 MFG: WAT  
MODEL: 0092MQT SERIAL NO: 208765  
EXISTING » EMD BID REFERENCE # BD0023134  
WATER PURVEYOR: COUNTY OF SACRAMENTO  
TYPE OF SERVICE: UNKNOWN (not desirable)

|          |  |                  |
|----------|--|------------------|
| FACILITY | FACILITY NAME: <u>ELK GROVE DENTAL</u>                         | PHONE:           |
|          | FACILITY ADDRESS: <u>9640 BRUCEVILLE RD ELK GROVE CA 95757</u> | <u>FA0044500</u> |
|          | ASSEMBLY LOCATION: <u>NSO BUILDING IN PL</u>                   |                  |

|                  |  |                              |
|------------------|--|------------------------------|
| OWNER / OPERATOR | OWNER NAME: <u>DONAHUE SCHRIER REALTY GROUP</u>  | PHONE: <u>(916) 920-5555</u> |
|                  | OPERATOR NAME: <u>ELK GROVE DENTAL</u>           | FAX NUMBER:                  |
|                  | MAILING ADDRESS: <u>3501 DEL PASO RD STE 100</u> |                              |
|                  | CITY, STATE, ZIP: <u>SACRAMENTO CA 95835</u>     | OWNER ID: <u>OW0024427</u>   |

|                           |
|---------------------------|
| OWNER/BUSINESS NO CHANGE? |
|---------------------------|

### DOUBLE CHECK VALVE ASSEMBLY

### TEST RESULTS INFORMATION

#### REDUCED PRESSURE PRINCIPLE ASSEMBLY

#### PRESSURE VACUUM BREAKER

#### CHECK VALVE NO. 1

#### CHECK VALVE NO. 2

#### DIFFERENTIAL RELIEF VALVE

#### AIR INLET VALVE

#### CHECK VALVE

|              |                              |  |  |  |  |
|--------------|------------------------------|--|--|--|--|
| INITIAL TEST | HELD AT: <u>8.60</u><br>PSID | HELD AT: <u>PSID</u><br>CLOSED TIGHT (RP) <u>Y</u><br>LEAKED: <u>N</u> | OPENED AT: <u>3.30</u><br>PSID<br>OPENED UNDER 2.0 PSID OR DID NOT OPEN <u>N</u> | OPENED AT: <u>PSID</u><br>OPENED UNDER 1.0 PSID OR DID NOT OPEN <u>N</u> | HELD AT: <u>PSID</u><br>LEAKED: <u>N</u> |
|              |                              |  |  |  |  |

#### TEST DATE

7/7/2015

COMMENTS: Annual Test!!!

STATUS: PASSED

TAG NO: CO2495

|                                 |                          |
|---------------------------------|--------------------------|
| SACRAMENTO COUNTY TESTER NUMBER | NAME                     |
| <u>PI0001026</u>                | <u>RAMIRO CUEVAS JR.</u> |

If the test **PASSES**, the field testing report(s) shall be filed with EMD within 20 calendar days following completion of the field test.

If the test **FAILS**, the tester shall report all failed results to EMD and to the water supplier within 24 hours. The tester shall submit all failed testing report(s) to EMD within five (5) calendar days following completion of the field test.

Failure to submit testing results may result in enforcement action.

SUBMITTED TO EMD ON: 7/10/2015 [PROCESS DATE]

