

COUNTY OF SACRAMENTO
ENVIRONMENTAL MANAGEMENT DEPARTMENT
ENVIRONMENTAL COMPLIANCE DIVISION
10590 ARMSTRONG AVENUE
MATHER CA 95655
(916) 875-0083 • FAX (916) 854-9274

BACKFLOW ASSEMBLY TEST REPORT

ASSEMBLY INFORMATION

TYPE: RP SIZE: 2.00 MFG: WAT
MODEL: 0092MQT SERIAL NO: 206374
EXISTING » EMD BID REFERENCE # BD0023133
WATER PURVEYOR: COUNTY OF SACRAMENTO
TYPE OF SERVICE: UNKNOWN (not desirable)

FACILITY	FACILITY NAME: <u>SLEEP TRAIN</u>	PHONE:
	FACILITY ADDRESS: <u>9660 BRUCEVILLE RD ELK GROVE CA 95757</u>	<u>FA0044499</u>
	ASSEMBLY LOCATION: <u>NE CORNER OF BUILDING</u>	

OWNER / OPERATOR	OWNER NAME: <u>DONAHUE SCHRIER REALTY</u>	PHONE:
	OPERATOR NAME: <u>SLEEP TRAIN</u>	FAX NUMBER:
	MAILING ADDRESS: <u>PO BOX 19703</u>	
	CITY, STATE, ZIP: <u>IRVINE CA 92623</u>	OWNER ID: <u>OW0026910</u>

OWNER/BUSINESS NO CHANGE?

INITIAL TEST	DOUBLE CHECK VALVE ASSEMBLY		TEST RESULTS INFORMATION		
	REDUCED PRESSURE PRINCIPLE ASSEMBLY		PRESSURE VACUUM BREAKER		
	CHECK VALVE NO. 1	CHECK VALVE NO. 2	DIFFERENTIAL RELIEF VALVE	AIR INLET VALVE	CHECK VALVE
	HELD AT: <u>9.10</u> PSID LEAKED: <u>N</u>	HELD AT: <u>PSID</u> CLOSED TIGHT (RP) <u>Y</u> LEAKED: <u>N</u>	OPENED AT: <u>3.30</u> PSID OPENED UNDER 2.0 PSID OR <u>N</u> DID NOT OPEN	OPENED AT: <u>PSID</u> OPENED UNDER 1.0 PSID OR <u>N</u> DID NOT OPEN	HELD AT: <u>PSID</u> LEAKED: <u>N</u>

TEST DATE
<u>6/27/2013</u>

COMMENTS: Annual Test!!!

STATUS: PASSED

TAG NO: CG4022

SACRAMENTO COUNTY TESTER NUMBER	NAME
<u>PI0000333</u>	<u>STEPHEN LeDOUX</u>

If the test **PASSES**, the field testing report(s) shall be filed with EMD within 20 calendar days following completion of the field test.

If the test **FAILS**, the tester shall report all failed results to EMD and to the water supplier within 24 hours. The tester shall submit all failed testing report(s) to EMD within five (5) calendar days following completion of the field test.

Failure to submit testing results may result in enforcement action.

SUBMITTED TO EMD ON: 7/1/2013 [PROCESS DATE]

