COUNTY OF SACRAMENTO ENVIRONMENTAL MANAGEMENT DEPARTMENT ENVIRONMENTAL COMPLIANCE DIVISION 10590 ARMSTRONG AVENUE MATHER CA 95655 (916) 875-0083 • FAX (916) 854-9274 ASSEMBLY INFORMATION

TYPE: RP SIZE: 1.50 MFG: FEB

MODEL: 825YA SERIAL NO: H004397

EXISTING » EMD BID REFERENCE # BD0021430

WATER PURVEYOR: COUNTY OF SACRAMENTO

TYPE OF SERVICE: IRRIGATION

## **BACKFLOW ASSEMBLY TEST REPORT**

<b>\</b>	FACILITY NAME:	CARL'S JR	PHONE:			
FACILITY	FACILITY ADDRESS:	9664 BRUCEVILLE RD ELK GROVE CA 95757		FA0027708		
FA	ASSEMBLY LOCATION:	SW CORNER OF BUILDING				
OWNER / OPERATOR	OWNER NAME:	DONAHUE SCHRIBER REALTY	PHONE:	<u>(714) 545-1400</u>		
	OPERATOR NAME:	CARL'S JR	FAX NUMBER:			
WN PER,	MAILING ADDRESS:	200 E BAKER ST, STE 100				
OB	CITY,STATE,ZIP:	COSTA MESA CA 92626	OWNER ID:	<u>OW0044313</u>		
	OWNER/BUSINESS	NO		1		
	CHANGE?					

	DOUBLE CHECK VALVE ASSEMBLY		TEST RESULTS INFORMATION			
	REDUCED	PRESSURE PRINCIPL	E ASSEMBLY	PRESSURE VACUUM BREAKER		
-	CHECK VALVE NO. 1	CHECK VALVE NO. 2	DIFFERENTIAL RELIEF VALVE	AIR INLET VALVE	CHECK VALVE	
INITIAL TEST	HELD AT: 7.20 PSID	HELD AT: PSID CLOSED TIGHT (RP) Y	OPENED AT: 3.00 PSID OPENED UNDER	OPENED AT:  PSID OPENED UNDER	HELD AT:	
	LEAKED: <u>N</u>	LEAKED: N	2.0 PSID OR NOT OPEN	1.0 PSID OR N DID NOT OPEN	LEAKED: <u>N</u>	

**TEST DATE** 8/17/2016 COMMENTS:

STATUS: PASSED TAG NO: CT2551

SACRAMENTO COUNTY TESTER NUMBER	NAME
PI0000558	BRYANT BOGREN

If the test PASSES, the field testing report(s) shall be filed with EMD within 20 calendar days following completion of the field test.

If the test FAILS, the tester shall report all failed results to EMD and to the water supplier within 24 hours. The tester shall submit all failed testing report(s) to EMD within five (5) calendar days following completion of the field test.

Failure to submit testing results may result in enforcement action.

SUBMITTED TO EMD ON: 8/22/2016 [PROCESS DATE]

