

COUNTY OF SACRAMENTO  
ENVIRONMENTAL MANAGEMENT DEPARTMENT  
ENVIRONMENTAL COMPLIANCE DIVISION  
10590 ARMSTRONG AVENUE  
MATHER CA 95655  
(916) 875-0083 • FAX (916) 854-9274

## BACKFLOW ASSEMBLY TEST REPORT

### ASSEMBLY INFORMATION

TYPE: RP SIZE: 2.00 MFG: WAT  
MODEL: 009MQT SERIAL NO: 210082  
EXISTING » EMD BID REFERENCE # BD0023129  
WATER PURVEYOR: COUNTY OF SACRAMENTO  
TYPE OF SERVICE: DOMESTIC

FACILITY	FACILITY NAME: <u>TRADER JOE'S STORES</u>	PHONE:
	FACILITY ADDRESS: <u>9670 BRUCEVILLE RD ELK GROVE CA 95758</u>	<u>FA0027986</u>
	ASSEMBLY LOCATION: <u>NSO 9670 BRUCEVILLE RD</u>	

OWNER / OPERATOR	OWNER NAME: <u>TRADER JOE'S STORES</u>	PHONE:
	OPERATOR NAME: <u>TRADER JOE'S STORES</u>	FAX NUMBER:
	MAILING ADDRESS: <u>PO BOX 5049</u>	
	CITY, STATE, ZIP: <u>MONROVIA CA 91017</u>	OWNER ID: <u>OW0027255</u>

OWNER/BUSINESS NO CHANGE?
------------------------------

### DOUBLE CHECK VALVE ASSEMBLY

### TEST RESULTS INFORMATION

#### REDUCED PRESSURE PRINCIPLE ASSEMBLY

#### PRESSURE VACUUM BREAKER

#### CHECK VALVE NO. 1

#### CHECK VALVE NO. 2

#### DIFFERENTIAL RELIEF VALVE

#### AIR INLET VALVE

#### CHECK VALVE

INITIAL TEST	HELD AT: <u>8.50</u> PSID	HELD AT: <u>PSID</u> CLOSED TIGHT (RP) <u>Y</u> LEAKED: <u>N</u>	OPENED AT: <u>2.20</u> PSID OPENED UNDER 2.0 PSID OR <u>N</u> DID NOT OPEN	OPENED AT: <u>PSID</u> OPENED UNDER 1.0 PSID OR <u>N</u> DID NOT OPEN	HELD AT: <u>PSID</u> LEAKED: <u>N</u>

#### TEST DATE

8/17/2016

#### COMMENTS:

STATUS: PASSED

TAG NO: CT 4646

SACRAMENTO COUNTY TESTER NUMBER	NAME
PI0001224	SETH THOMAS

If the test **PASSES**, the field testing report(s) shall be filed with EMD within 20 calendar days following completion of the field test.

If the test **FAILS**, the tester shall report all failed results to EMD and to the water supplier within 24 hours. The tester shall submit all failed testing report(s) to EMD within five (5) calendar days following completion of the field test.

Failure to submit testing results may result in enforcement action.

SUBMITTED TO EMD ON: 8/30/2016 [PROCESS DATE]

