

COUNTY OF SACRAMENTO
ENVIRONMENTAL MANAGEMENT DEPARTMENT
ENVIRONMENTAL COMPLIANCE DIVISION
10590 ARMSTRONG AVENUE
MATHER CA 95655
(916) 875-0083 • FAX (916) 854-9274

BACKFLOW ASSEMBLY TEST REPORT

ASSEMBLY INFORMATION

TYPE: RP SIZE: 1.50 MFG: WIL
MODEL: 975XL SERIAL NO: 1892818
EXISTING » EMD BID REFERENCE # BD0014572
WATER PURVEYOR: COUNTY OF SACRAMENTO
TYPE OF SERVICE: DOMESTIC

FACILITY	FACILITY NAME: <u>TRADER JOE'S STORES</u>	PHONE:
	FACILITY ADDRESS: <u>9670 BRUCEVILLE RD ELK GROVE CA 95758</u>	<u>FA0027986</u>
	ASSEMBLY LOCATION: <u>ON ROOF</u>	

OWNER / OPERATOR	OWNER NAME: <u>TRADER JOE'S STORES</u>	PHONE:
	OPERATOR NAME: <u>TRADER JOE'S STORES</u>	FAX NUMBER:
	MAILING ADDRESS: <u>PO BOX 5049</u>	
	CITY, STATE, ZIP: <u>MONROVIA CA 91017</u>	OWNER ID: <u>OW0027255</u>

OWNER/BUSINESS NO CHANGE?

DOUBLE CHECK VALVE ASSEMBLY

TEST RESULTS INFORMATION

REDUCED PRESSURE PRINCIPLE ASSEMBLY

PRESSURE VACUUM BREAKER

CHECK VALVE NO. 1

CHECK VALVE NO. 2

DIFFERENTIAL RELIEF VALVE

AIR INLET VALVE

CHECK VALVE

INITIAL TEST	HELD AT: <u>8.80</u> PSID	HELD AT: <u>PSID</u> CLOSED TIGHT (RP) <u>Y</u> LEAKED: <u>N</u>	OPENED AT: <u>3.80</u> PSID OPENED UNDER 2.0 PSID OR <u>N</u> DID NOT OPEN	OPENED AT: <u>PSID</u> OPENED UNDER 1.0 PSID OR <u>N</u> DID NOT OPEN	HELD AT: <u>PSID</u> LEAKED: <u>N</u>

TEST DATE

1/26/2015

COMMENTS:

STATUS: PASSED

TAG NO: cn0260

SACRAMENTO COUNTY TESTER NUMBER	NAME
PI0001074	MATTHEW SPELLMAN

If the test **PASSES**, the field testing report(s) shall be filed with EMD within 20 calendar days following completion of the field test.

If the test **FAILS**, the tester shall report all failed results to EMD and to the water supplier within 24 hours. The tester shall submit all failed testing report(s) to EMD within five (5) calendar days following completion of the field test.

Failure to submit testing results may result in enforcement action.

SUBMITTED TO EMD ON: 1/27/2015 [PROCESS DATE]

